

DATE

02/01/2014

PRODUCER

REM

CUSTOMER

CARTIERE_DI_GUARCINO

PRODUCT

CAMPI_ARMATURA_E_COMPEN

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Monophasic	0.01	0.03	0.02037	8.509	0	6	0.3	

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Monophasic	442	2	0.000 u	100	5		100	GO	
Sample	442		0.000 u			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
				N.E.

MEGAOHMMETER TEST

	V (V)	R Min [kOhm]	R Meas [kOhm]	Result
				N.E.

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

