

DATE

27/12/2013

PRODUCER

REM

CUSTOMER

CARTIERE BURGO SORA

PRODUCT

ABB HXR355LE4 B3

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	1	2	1.68316	7.31	PASS	5	0.5	PASS
Phase 2			1.69139		PASS			
Phase 3			1.68728		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	5785	2	205.4 m	0.6	3	74.03	1.3	GO	98.1
Phase 2	5678		206.7 m			74.03		GO	
Phase 3	5732		205.4 m			73.08		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	6035	0.004	1	GO

MEGAOHMMETER TEST

	V (V)	R Min [kOhm]	R Meas [kOhm]	Result
	6136	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

