

DATE

27/12/2013

PRODUCER

REM

CUSTOMER

CARTIERE BURGO SORA

PRODUCT

SIEMENS 1LA8453-4PC50-Z 450

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0.002	0.01	0.00925	11.13	PASS	5	2.3	PASS
Phase 2			0.0092		PASS			
Phase 3			0.00941		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	971	2	615.5 u	0.5	3	50	0	GO	99.5
Phase 2	971		612.5 u			50		GO	
Phase 3	957		614.0 u			50		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1042	0	1	GO

MEGAOHMMETER TEST

	V (V)	R Min [kOhm]	R Meas [kOhm]	Result
	1042	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

