

DATE

31/12/2013

PRODUCER

REM

CUSTOMER

CARTIERE BURGO SORA

PRODUCT

ROTORE MOTORE VEM SPEH

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1907	2	1.726 m	0.9	5	40.32	2.3	GO	96.8
Phase 2	1907		1.733 m			40.32		GO	
Phase 3	1907		1.718 m			41.27		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1055	0	1	GO

MEGAOHMMETER TEST

	V (V)	R Min [kOhm]	R Meas [kOhm]	Result
	1042	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

