

DATE

31/12/2013

PRODUCER

REM

CUSTOMER

CARTIERE BURGO SORA

PRODUCT

STATORE MOTORE VEM

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0.04	0.09	0.06735	8.243	PASS	5	1.2	PASS
Phase 2			0.06796		PASS			
Phase 3			0.06815		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1800	2	774.6 u	0	5	36.21	4.8	GO	95.2
Phase 2	1821		774.6 u			34.48		GO	
Phase 3	1800		774.6 u			36.21		GO	
Sample	585		228.1			75.68			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1042	0	1	GO

MEGAOHMMETER TEST

	V (V)	R Min [kOhm]	R Meas [kOhm]	Result
	1042	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

