



CSA INTERNATIONAL

Certificate of Compliance

Certificate Number: LR 31928-537

Revision: LR 31928-615

Date Issue: August 13, 1999

Issued to: **OMRON ELECTRONICS, INC.**
ONE EAST COMMERCE DR.
SCHAUMBURG, IL 60173
USA
ATTENTION: MR. JIM ZIELINSKI

*¹The products listed below are eligible to bear the CSA Mark shown,
with adjacent indicator NRTL/C.*



Issued by: J. Lam, C.E.T.

Signature: _____

PRODUCTS

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

CLASS 3211 87 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus - CERTIFIED TO U.S. STANDARDS

CLASS 3211 04 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Magnetic

CLASS 3211 84 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Magnetic - CERTIFIED TO U.S. STANDARDS

Relays, alternate type of Type G2R-1 and G2R-2 with suffixes, open type, with dust cover, coils 3 through 240V ac and 3 through 110V dc. Max ratings as follows:

¹The "NRTL/C" indicator adjacent to the CSA Mark signifies that the product has been evaluated to the applicable ANSI/UL and CSA Standards, for use in the U.S. and Canada. NRTL, i.e. Nationally Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.