SIEMENS

Product data sheet

3TK2825-1BB40



SIRIUS SAFETY RELAY WITH RELAY RELEASE CIRCUITS (RC), DC 24V, 45.0MM, SCREW TERMINAL, RC INSTANT.: 3NO, RC DELAYED: 0NO, MK: 2NC, AUTOSTART / MONITORED START, BASIC DEVICE, MAX. ACHIEVABLE SIL: 3, PL: E

| General | tech | nical | detai | ls: |
|---------|------|-------|-------|-----|

| product brand name | | SIRIUS |
|--|-----|--------------------------|
| product designation | | safety relays |
| Design of the product | | for EMERGENCY-STOP units |
| protection class IP / of the housing | | IP20 |
| Protection class IP / of the terminal | | IP20 |
| Protection against electrical shock | | finger-safe |
| Insulation voltage / rated value | V | 300 |
| Ambient temperature | | |
| during storage | °C | -40 +80 |
| during operating | °C | -25 +60 |
| Air pressure | | |
| according to SN 31205 | kPa | 90 106 |
| Relative humidity | | |
| during operating phase | % | 10 95 |
| Installation altitude / at a height over sea level / maximum | m | 2,000 |
| Resistance against vibration / according to IEC 60068-2-6 | | 5 500 Hz: 0,075 mm |
| Resistance against shock | | 8g / 10 ms |
| Impulse voltage resistance / rated value | V | 4,000 |
| EMC emitted interference | | EN 60947-5-1 |
| | | |

| Installation environment relating to EMC | | This product is suitable for Class A environments only. It can cause undesired radio-frequency interference in residential environments. If this is the case, the user must take appropriate measures. |
|---|-----|---|
| Item designation | | |
| according to DIN 40719 extendable after IEC 204-2 / according to IEC 750 | | КТ |
| according to DIN EN 61346-2 | | F |
| Number of sensor inputs | - | |
| 1-channel or 2-channel | | 1 |
| Design of the cascading | | none |
| Type of the safety-related wiring / of the inputs | | single-channel and two-channel |
| Product feature / transverse contact-secure | | Yes |
| Safety Integrity Level (SIL) | | |
| according to IEC 61508 | | SIL3 |
| SIL claim limit (for a subsystem) / according to EN 62061 | | 3 |
| Performance Level (PL) | | |
| according to ISO 13849-1 | | е |
| Category / according to EN 954-1 | | 4 |
| Category / according to ISO 13849-1 | | 4 |
| Hardware fault tolerance / according to IEC 61508 | | 1 |
| Safety device type / according to IEC 61508-2 | - | Туре А |
| Probability of dangerous failure per hour (PFHD) / with high demand rate / according to EN 62061 | 1/h | 0.15E-8 |
| Average probability of failure on demand (PFDavg) / with low demand rate / according to IEC 61508 | 1/у | 0.13E-5 |
| T1 value / for proof test interval or service life / according to IEC 61508 | а | 20 |
| Number of outputs / as contact-affected switching element | | |
| as NC contact / for reporting function / instantaneous switching | | 2 |
| as NO contact / safety-related / instantaneous switching | | 3 |
| as NO contact / safety-related / delayed switching | | 0 |
| Number of outputs / as contact-less semiconductor switching element | | |
| • safety-related | | |
| delayed switching | | 0 |
| non-delayed | | 0 |
| for reporting function | | |
| delayed switching | | 0 |
| • non-delayed | | 0 |
| Stop category / according to DIN EN 60204-1 | | 0 |

| Design of the input | | |
|--|-----|----------------------------|
| cascading-input/functional switching | | No |
| • feedback input | | Yes |
| • start input | | Yes |
| Design of the electrical connection / jumper socket | | Yes |
| Operating cycles / maximum | 1/h | 1,000 |
| Switching capacity current | | |
| of NO contacts of relay outputs | | |
| • at DC-13 | | |
| • at 24 V | А | 6 |
| • at 115 V | А | 0.2 |
| • at 230 V | А | 0.1 |
| • at AC-15 | | |
| • at 115 V | А | 6 |
| • at 230 V | А | 6 |
| of NC contacts of relay outputs | | |
| • at DC-13 | | |
| • at 24 V | А | 6 |
| • at 115 V | А | 0.2 |
| • at 230 V | А | 0.1 |
| • at AC-15 | | |
| • at 115 V | А | 6 |
| • at 230 V | А | 6 |
| Thermal current / of the contact-affected switching element / maximum | A | 6 |
| Electrical operating cycles as operating time / typical | - | 100,000 |
| Mechanical operating cycles as operating time / typical | | 10,000,000 |
| Design of the fuse link / for short-circuit protection of the NO contacts of the relay outputs / required | | gL/gG: 6 A, or quick: 10 A |
| Resistance to direct current / of the cable / maximum | Ω | 30 |
| Cable length / between sensor and electronic evaluation device / with Cu 1.5 mm ² and 150 nF/km / maximum | m | 1,000 |
| Make time / with automatic start | | |
| • for AC / maximum | ms | 150 |
| Make time / with monitored start | | |
| • maximum | ms | 25 |
| Backslide delay time / at mains power cut | | |
| • maximum | ms | 350 |
| Recovery time / after opening of the safety circuits / typical | ms | 200 |
| | | |

| Pulse duration | | | | |
|--|----|------------------------------------|--|--|
| of the sensor input / minimum | ms | 25 | | |
| of the ON pushbutton input / minimum | ms | 25 | | |
| Control circuit: | | | | |
| Type of voltage / of the controlled supply voltage | | DC | | |
| Control supply voltage / 1 / for DC / rated value | V | 24 | | |
| operating range factor control supply voltage rated value / of the magnet coil | | | | |
| • at 50 Hz | | | | |
| • for AC | | 0.85 1.1 | | |
| • at 60 Hz | | | | |
| • for AC | | 0.85 1.1 | | |
| • for DC | | 0.85 1.1 | | |
| Installation/mounting/dimensions: | | | | |
| mounting position | | any | | |
| Type of mounting | | screw and snap-on mounting | | |
| Width | mm | 44.8 | | |
| Height | mm | 138.5 | | |
| Depth | mm | 120 | | |
| Connections: | | | | |
| Design of the electrical connection | | screw-type terminals | | |
| Type of the connectable conductor cross-section | | | | |
| • solid | | 1x (0.5 4 mm²), 2x (0.5 2.5 mm²) | | |
| finely stranded | | | | |
| • with wire end processing | | 1x (0.5 2.5 mm²), 2x (0.5 1.5 mm²) | | |
| Type of the connectable conductor cross-sections / for AWG | | | | |

 conductors
 2x (20 ... 14)

 • solid
 2x (20 ... 14)

 • stranded
 2x (20 ... 14)

 Product Function:

 Product function
 Image: Standstill monitoring

 • light barrier monitoring
 No

 • standstill monitoring
 No

 • protective door monitoring
 Yes

 • automatic start
 Yes

 • magnetic switch monitoring Normally closed contact-Normally open contact
 No

 • rotation speed monitoring
 No

| laser scanner monitoring | No | | | |
|--|-----|--|--|--|
| monitored start-up | Yes | | | |
| light grid monitoring | No | | | |
| magnetic switch monitoring Normally closed contact-Normally closed contact | No | | | |
| emergency stop function | Yes | | | |
| step mat monitoring | Yes | | | |
| Suitability for interaction / pressing control | No | | | |
| Acceptability for application | | | | |
| monitoring of floating sensors | Yes | | | |
| monitoring of non-floating sensors | No | | | |
| safety cut-out switch | Yes | | | |
| position switch monitoring | Yes | | | |
| EMERGENCY-OFF circuit monitoring | Yes | | | |
| valve monitoring | No | | | |
| tactile sensor monitoring | No | | | |
| magnetically operated switches monitoring | No | | | |
| safety-related circuits | Yes | | | |
| Certificates/approvals: | | | | |

| Verification of suitability | BG, SUVA, UL, CSA, EN 60204-1, EN ISO 12100, EN 954-1, IEC 61508 | | |
|---|--|-----|--|
| TÜV (German technical inspectorate) certificate | Yes | | |
| UL-registration | Yes | | |
| BG BIA certificate | Yes | | |
| General Product Approval | | EMC | Functional Safety / Safety of Machinery |



| Declaration of Conformity | Test Certificates | other | | |
|------------------------------|-----------------------------|--------------|--------------------------------|--|
| CE | Special Test Certificate | Confirmation | Environmental Confirmations | |

Further information:

EG-Konf.


Information- and Downloadcenter (Catalogs, Brochures,...) http://www.siemens.com/industrial-controls/catalogs

Industry Mall (Online ordering system) http://www.siemens.com/industrial-controls/mall

Cax online generator: http://www.siemens.com/cax

Service&Support (Manuals, Certificates, Characteristics, FAQs,...) http://support.automation.siemens.com/WW/view/en/3TK2825-1BB40/all

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...) http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=3TK2825-1BB40



last change:

Oct 28, 2013

 \square

Π

 \square

Π

83-106.