

DATE

17/08/2022

PRODUCER

R.E.M. SRL

CUSTOMER

BLASETTI

PRODUCT

ABBM2BAT315SMB4
N_070906014519 N_COMM 2022

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.03023	30.82	PASS	7.7	0.2	PASS
Phase 2			0.03023		PASS			
Phase 3			0.03028		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1307	6.4	1.549 m	0.9	6.4	45.45	0	GO	99.1
Phase 2	1307		1.549 m			45.45		GO	
Phase 3	1307		1.535 m			45.45		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1079	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1080	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	803	321	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

