

DATE

24/01/2023

PRODUCER

R.E.M. SRL

CUSTOMER

BURGO SORA

PRODUCT

SIEMENS 1LA4312-4AN60Z
N°Comm 2022-0726

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	2.18949	9.976	PASS	7.7	0.2	PASS
Phase 2			2.18582		PASS			
Phase 3			2.18582		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	3910	6.4	227.7 m	1.9	6.4	73.08	2.6	GO	95.5
Phase 2	3910		226.7 m			74.51		GO	
Phase 3	3964		231.0 m			72.55		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	5121	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	5107	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

