

DATE

27/01/2023

PRODUCER

R.E.M. SRL

CUSTOMER

BUZZI GUIDONIA

PRODUCT

STATORE ANSALDO CTF630K6
N°Comm 20230045

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.11225	15.26	PASS	7.7	0.2	PASS
Phase 2			0.11197		PASS			
Phase 3			0.11215		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	3214	6.4	50.55 m	0.2	6.4	82.61	0	GO	99.8
Phase 2	3214		50.63 m			82.61		GO	
Phase 3	3214		50.60 m			82.61		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	4090	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	4104	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

