

DATE

03/03/2023

PRODUCER

R.E.M. SRL

CUSTOMER

BUZZI SINISCOLA

PRODUCT

Rotore ASEA MAF630S N°Comm
2023-0162

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.02143	12.73	PASS	7.7	2.4	PASS
Phase 2			0.02123		PASS			
Phase 3			0.02093		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1307	6.4	1.748 m	0.3	6.4	46.34	2.4	GO	97.3
Phase 2	1307		1.743 m			46.34		GO	
Phase 3	1307		1.743 m			45.24		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1460	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1474	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	964	535	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

