

DATE

03/03/2023

PRODUCER

R.E.M. SRL

CUSTOMER

BUZZI SINISCOLA

PRODUCT

statore ASEA MAF630S N°Comm
2023-0162

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.42843	12.29	PASS	7.7	0	PASS
Phase 2			0.4285		PASS			
Phase 3			0.42843		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	3482	6.4	54.84 m	0	6.4	73.68	3.4	GO	96.6
Phase 2	3482		54.85 m			73.68		GO	
Phase 3	3482		54.85 m			76.32		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	6124	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	6085	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

