

DATE

18/01/2023

PRODUCER

R.E.M. SRL

CUSTOMER

BUZZI PORTO MARGHERA

PRODUCT

Rotore ABB AML630 L6A BAM
2022-0937

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.0075	14.86	PASS	7.7	0.3	PASS
Phase 2			0.00751		PASS			
Phase 3			0.00749		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1092	6.4	1.505 m	0.3	6.4	64.44	0	GO	99.7
Phase 2	1092		1.505 m			64.44		GO	
Phase 3	1092		1.500 m			64.44		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1093	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1093	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

