

DATE

17/06/2022

PRODUCER

R.E.M. SRL

CUSTOMER

CLANIUS

PRODUCT

ABB 250M4 N B2C2542A00020 N°
COMM 2022 0315

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.11579	25.13	PASS	7.7	0.4	PASS
Phase 2			0.11575		PASS			
Phase 3			0.11536		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	878	6.4	1.716 m	1.7	5	43.75	0	GO	98.3
Phase 2	878		1.689 m			43.75		GO	
Phase 3	878		1.718 m			43.75		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1042	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1042	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	857	428	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

