

DATE

03/08/2022

PRODUCER

R.E.M. SRL

CUSTOMER

TRELLEBORG

PRODUCT

HELMKE DOR680 4_6
N11000078041 Comm 2022 0233 (4)

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.41116	29.35	PASS	7.7	0	PASS
Phase 2			0.41109		PASS			
Phase 3			0.41109		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	4500	6.4	50.25 m	1.2	5	63.16	4.2	GO	94.6
Phase 2	4571		50.28 m			60.53		GO	
Phase 3	4571		49.67 m			61.54		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	5121	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	5095	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

