

DATE

25/02/2021

PRODUCER

ESI SERVICE

CUSTOMER

CER CONSORZIO PANTALONE

PRODUCT

TIBB QOV630ob8 N°M000017-2
1300KW

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.13162	15.71	PASS	5	0.2	PASS
Phase 2			0.13164		PASS			
Phase 3			0.13144		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	2642	3	15.20 m	0.8	5.6	58.62	0	GO	99.2
Phase 2	2642		15.24 m			58.62		GO	
Phase 3	2642		15.12 m			58.62		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	3074	0.004	0.36	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	3088	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

