

DATE

25/06/2020

PRODUCER

R.E.M. SRL

CUSTOMER

HENKEL

PRODUCT

motore leroy somer commessa 2020-0373

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1521	4	377.8 u	0.6	10.9	26.09	7.7	GO	91.7
Phase 2	1521		380.2 u			27.66		GO	
Phase 3	1500		380.2 u			28.26		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	2070	0.004	0.284	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	2084	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	1035	678	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

