

DATE

25/06/2020

PRODUCER

R.E.M. SRL

CUSTOMER

HENKEL

PRODUCT

TECNOMASIO COMMESSA 2020-0372

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1478	4	546.2 u	0.8	10.9	36.54	0	GO	99.2
Phase 2	1478		546.2 u			36.54		GO	
Phase 3	1478		550.4 u			36.54		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	2083	0.004	0.284	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	2097	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	1428	857	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

