

DATE

17/01/2023

PRODUCER

R.E.M. SRL

CUSTOMER

HYDRO ALLUMINIUM

PRODUCT

VENTILATORE SIEMENS 1LE1503
2AA43 4AB4 N°Comm 2023-0017

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.12139	14.33	PASS	7.7	0.2	PASS
Phase 2			0.12137		PASS			
Phase 3			0.12117		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1478	6.4	4.201 m	2.9	6.4	60.34	1.2	GO	95.9
Phase 2	1478		4.201 m			60.34		GO	
Phase 3	1478		4.326 m			59.65		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1117	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1118	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	1017	535	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

