

DATE

28/09/2022-----

PRODUCER

R.E.M. SRL

CUSTOMER

TEFIN

PRODUCT

STATORE ALTERNATORE LEROY
SOMER LSA47 2M7C6 4 N_342336

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.00927	18.95	PASS	7.7	0.1	PASS
Phase 2			0.00926		PASS			
Phase 3			0.00926		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1242	6.4	395.6 u	0.3	6.4	31.71	0	GO	99.7
Phase 2	1242		396.8 u			31.71		GO	
Phase 3	1242		396.8 u			31.71		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1079	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1080	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	696	428	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

