

DATE

22/02/2022

PRODUCER

R.E.M. SRL

CUSTOMER

BURGO SORA

PRODUCT

SIEMENS 1LA8403 6PB50 Z 400
N°Comm 2021-0756

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.00679	16.33	PASS	5	0.4	PASS
Phase 2			0.00678		PASS			
Phase 3			0.00676		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	985	6.2	744.9 u	1.3	6.5	46.94	2	GO	96.7
Phase 2	985		746.6 u			46.94		GO	
Phase 3	985		754.8 u			46		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1104	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1106	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	535	321	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

