

DATE

26/07/2021

PRODUCER

R.E.M. SRL

CUSTOMER

BUZZI SINISCOLA

PRODUCT

Rotore ASEA MAF450M N°7070108
N°Comm 2021-0441

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.01801	27.17	PASS	5	0.8	PASS
Phase 2			0.01803		PASS			
Phase 3			0.01815		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1285	6.2	763.0 u	0.2	6.5	46.97	1.7	GO	98.1
Phase 2	1300		764.7 u			47.76		GO	
Phase 3	1300		763.0 u			47.76		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1106	0	0.584	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1118	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	750	428	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

