

DATE

23/07/2021

PRODUCER

R.E.M. SRL

CUSTOMER

BUZZI SINISCOLA

PRODUCT

Statore ASEA MAF450M
N°7070108 N°Comm 2021-0441

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.01128	25.17	PASS	5	1.1	PASS
Phase 2			0.01118		PASS			
Phase 3			0.01116		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1185	3.6	554.6 u	0.3	6.5	39.06	1.6	GO	98.1
Phase 2	1171		556.0 u			39.68		GO	
Phase 3	1171		554.6 u			39.06		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1093	0	0.584	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1093	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	750	428	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

