

DATE

31/03/2022

PRODUCER

R.E.M. SRL

CUSTOMER

RCR CRISTALLERIA

PRODUCT

LEROY SOMER LSP 315S N_18598
1 N COM 2021 0624

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.04097	15.66	PASS	5	0.4	PASS
Phase 2			0.04112		PASS			
Phase 3			0.04107		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	964	10	1.253 m	0.2	10.7	43.75	0	GO	99.8
Phase 2	964		1.250 m			43.75		GO	
Phase 3	964		1.253 m			43.75		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1587	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1588	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	1321	750	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

