

DATE

25/01/2022

PRODUCER

R.E.M. SRL

CUSTOMER

BURGO AVEZZANO

PRODUCT

SIEMENS 1LA8315 N°Comm 2022-0054

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.02504	15.84	PASS	5	0.2	PASS
Phase 2			0.02504		PASS			
Phase 3			0.02499		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1328	6.2	1.200 m	1.2	6.5	47.92	0	GO	98.8
Phase 2	1350		1.215 m			47.92		GO	
Phase 3	1328		1.204 m			47.92		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1066	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1067	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	535	214	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

