

DATE

09/01/2023

PRODUCER

R.E.M. SRL

CUSTOMER

BUZZI

PRODUCT

Statore ABB ML630L6A BAM N
Comm 2022 0937 N Rem 14914

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.06301	14.6	PASS	7.7	0.2	PASS
Phase 2			0.06291		PASS			
Phase 3			0.06301		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	2107	6.4	3.060 m	0.4	6.4	287.5	0	GO	99.6
Phase 2	2107		3.066 m			287.5		GO	
Phase 3	2071		3.073 m			287.5		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1067	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1042	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	964	482	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

