

DATE

16/12/2022

PRODUCER

R.E.M. SRL

CUSTOMER

BONIFICA SUD OVEST

PRODUCT

FLYGT 7061 705 N°9971018
N°Comm 2022-0796

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.06623	16.37	PASS	7.7	1.5	PASS
Phase 2			0.06523		PASS			
Phase 3			0.06525		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1371	6.4	1.468 m	0.5	6.4	45.65	2.2	GO	97.3
Phase 2	1350		1.475 m			46.67		GO	
Phase 3	1371		1.475 m			46.67		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1053	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1067	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	857	321	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

