

DATE

23/03/2022

PRODUCER

R.E.M. SRL

CUSTOMER

HYDRO

PRODUCT

SEIPEE MG225S 4 N Comm 2022
0187 N Rem 15659 (prima del

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.12959	16.6	PASS	5	0.9	PASS
Phase 2			0.13078		PASS			
Phase 3			0.13038		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1457	10	2.839 m	0.9	10.7	57.41	3.1	GO	96
Phase 2	1435		2.846 m			57.41		GO	
Phase 3	1435		2.820 m			59.26		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1091	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1093	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	910	428	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

