

DATE

23/03/2022

PRODUCER

R.E.M. SRL

CUSTOMER

INT. PAPER

PRODUCT

ELECTRO ADDA 200L 4 KW30 N
Comm 2022 0215 N Rem 15672

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.24821	15.26	PASS	5	3.4	PASS
Phase 2			0.25658		PASS			
Phase 3			0.25658		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1478	10	3.700 m	0.7	10.7	58.62	2.9	GO	96.4
Phase 2	1478		3.703 m			58.62		GO	
Phase 3	1478		3.725 m			60.34		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1130	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1144	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	964	482	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

