

DATE

03/03/2022

PRODUCER

R.E.M. SRL

CUSTOMER

ITALCEMENTI S P A

PRODUCT

SENZA TARGA KW_110 POLI_4
N_REM 15621 N_COM 20220070

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.02638	15.4	PASS	5	0.4	PASS
Phase 2			0.02628		PASS			
Phase 3			0.02638		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1271	6.2	1.131 m	0.5	6.5	42.42	0	GO	99.5
Phase 2	1285		1.137 m			42.42		GO	
Phase 3	1271		1.135 m			42.42		GO	
Sample	642		0.725			40.5			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1091	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1106	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	857	482	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

