

DATE

08/11/2022

PRODUCER

R.E.M. SRL

CUSTOMER

SORGENIA

PRODUCT

ANSALDO CT 560 Y2 N_123707
N_Comm 2022 0816

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.11866	15.35	PASS	7.7	0.3	PASS
Phase 2			0.11828		PASS			
Phase 3			0.11828		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	4071	6.4	68.79 m	0.5	6.4	64.86	4	GO	95.5
Phase 2	4017		68.79 m			64.86		GO	
Phase 3	4071		69.16 m			67.57		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	4955	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	4968	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

