

DATE

22/02/2023

PRODUCER

R.E.M. SRL

CUSTOMER

SORGENIA POWER

PRODUCT

MARELLI A6C18M2 N COMM 2022
0869 N REM 15601

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.36264	15.49	PASS	7.7	0.1	PASS
Phase 2			0.36224		PASS			
Phase 3			0.36224		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1328	6.4	5.833 m	0.3	6.4	69.23	1.9	GO	97.8
Phase 2	1328		5.815 m			67.92		GO	
Phase 3	1328		5.815 m			67.92		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1029	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1029	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	928	500	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

