

DATE

26/06/2023

PRODUCER

R.E.M. SRL

CUSTOMER

A.R.I.A.

PRODUCT

SEIPEE GM 315LB 4 B3 N COMM
2023 0521 N REM 16168

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.01271	27.08	PASS	7.7	0.9	PASS
Phase 2			0.0126		PASS			
Phase 3			0.01272		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1157	5.2	723.9 u	1.8	5	39.02	0	GO	98.2
Phase 2	1157		723.9 u			39.02		GO	
Phase 3	1157		711.0 u			39.02		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1055	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1054	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	696	321	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

