

DATE

17/02/2023

PRODUCER

R.E.M. SRL

CUSTOMER

A.R.I.A

PRODUCT

SEIPEE GM250M2 N REM 15979 N
COMM 2023 0116

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.05867	13.98	PASS	7.7	0.2	PASS
Phase 2			0.05868		PASS			
Phase 3			0.05877		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1285	6.4	1.816 m	0.7	6.4	54	0	GO	99.3
Phase 2	1307		1.818 m			54		GO	
Phase 3	1285		1.806 m			54		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1053	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1055	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	857	428	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

