

DATE

20/03/2023

PRODUCER

R.E.M. SRL

CUSTOMER

A.R.I.A. S.P.A.

PRODUCT

SEIPEE GM250M 2 N COMM 2023
0226 N REM 16033

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.06035	14.51	PASS	7.7	0.6	PASS
Phase 2			0.06074		PASS			
Phase 3			0.06044		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1350	2.4	1.859 m	0.4	5	53.85	0	GO	99.6
Phase 2	1328		1.859 m			53.85		GO	
Phase 3	1350		1.852 m			53.85		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1055	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1067	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	857	428	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

