

DATE

03/07/2023

PRODUCER

R.E.M. SRL

CUSTOMER

A.R.I.A.

PRODUCT

SEIPEE GM 315LB 4 B3 N°Comm
2023-0521

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.01275	24.02	PASS	7.7	1.5	PASS
Phase 2			0.01294		PASS			
Phase 3			0.01279		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1285	5.2	723.9 u	0.2	5	42.22	0	GO	99.8
Phase 2	1285		725.5 u			42.22		GO	
Phase 3	1285		723.9 u			42.22		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1131	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1131	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	589	321	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

