

DATE

03/07/2023

PRODUCER

R.E.M. SRL

CUSTOMER

A.R.I.A.

PRODUCTSIEMENS 1AV3205B
1LE10032AB534AA4 N°Comm 2023-**RESISTANCE TEST**

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.14052	25	PASS	7.7	0.1	PASS
Phase 2			0.14035		PASS			
Phase 3			0.14054		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	942	5.2	3.980 m	0.9	5	61.11	1.7	GO	97.4
Phase 2	964		3.947 m			62.16		GO	
Phase 3	985		3.984 m			62.16		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1106	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1105	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	910	535	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

