

DATE

11/09/2023

PRODUCER

R.E.M. SRL

CUSTOMER

ARIA

PRODUCT

SEIPEE GM 315LC N COMM 2023
0723 N REM 16263

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.02025	26.24	PASS	7.7	0.2	PASS
Phase 2			0.02029		PASS			
Phase 3			0.02027		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1328	5.2	789.7 u	0.2	5	34.88	8.4	GO	91.4
Phase 2	1328		788.0 u			34.09		GO	
Phase 3	1328		789.7 u			37.21		NO GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1053	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1055	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	964	535	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

