

DATE

12/02/2024

PRODUCER

R.E.M. SRL

CUSTOMER

BLASETTI

PRODUCT

MOT BACKER SENZA TARGA
Comm 2023 0984

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.04825	11.44	PASS	7.7	1	PASS
Phase 2			0.04875		PASS			
Phase 3			0.04825		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1242	5.2	681.0 u	0.5	6	40.91	0	GO	99.5
Phase 2	1242		682.6 u			40.91		GO	
Phase 3	1242		679.5 u			40.91		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1117	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1105	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	928	500	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

