

DATE

21/04/2023

PRODUCER

R.E.M. SRL

CUSTOMER

BURGO Avezzano

PRODUCT

POMPA FLYGT 2250 011 N_8831002 N_COMM 2023 0175

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.10004	15.71	PASS	7.7	0.6	PASS
Phase 2			0.09984		PASS			
Phase 3			0.10042		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1371	5.2	2.279 m	1.4	5	42.22	0	GO	98.6
Phase 2	1371		2.279 m			42.22		GO	
Phase 3	1371		2.248 m			42.22		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1130	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1131	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	964	428	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

