

DATE

27/03/2023

PRODUCER

R.E.M. SRL

CUSTOMER

BURGO Avezzano

PRODUCT

ABB M2BAX 355 SMB6 N COMM
2023 0176 N REM 16008 (prima)

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.01523	16.55	PASS	7.7	0.2	PASS
Phase 2			0.01521		PASS			
Phase 3			0.01521		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1114	5.2	846.1 u	1	5	46.15	0	GO	99
Phase 2	1114		837.4 u			46.15		GO	
Phase 3	1114		837.4 u			46.15		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1093	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1080	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	642	214	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

