

DATE

11/04/2023

PRODUCER

R.E.M. SRL

CUSTOMER

MARANGONI

PRODUCT

Motore ABB senza targa N Comm
2023 0234 N Rem 16036

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.0197	13.89	PASS	7.7	0.9	PASS
Phase 2			0.01955		PASS			
Phase 3			0.01953		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	964	5.2	307.7 u	2	5	25	0	GO	98
Phase 2	964		313.0 u			25		GO	
Phase 3	964		306.6 u			25		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1155	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1156	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	857	428	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

