

DATE

14/03/2023

PRODUCER

R.E.M. SRL

CUSTOMER

BURGO AVEZZANO

PRODUCT

SIEMENS 1LA8315 N Comm 2023
0197 N Rem 14872

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.0189	15.22	PASS	7.7	1.2	PASS
Phase 2			0.0187		PASS			
Phase 3			0.01892		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1007	2.4	1.409 m	0.5	5	58.33	2.8	GO	96.7
Phase 2	1007		1.416 m			60		GO	
Phase 3	1007		1.414 m			60		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1168	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1181	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	642	428	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

