

DATE

08/02/2023

PRODUCER

R.E.M. SRL

CUSTOMER

BURGO SORA

PRODUCT

SIEMENS 1LA8403 6PB50 Z 400
FORMA B3 N COMM 2023 0063 N

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.00671	9.398	PASS	7.7	0.8	PASS
Phase 2			0.00674		PASS			
Phase 3			0.00669		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1114	6.4	707.8 u	1.6	6.4	45.95	0	GO	98.4
Phase 2	1114		707.8 u			45.95		GO	
Phase 3	1071		719.0 u			45.95		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1142	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1144	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	571	357	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)
	úÚú± ¶lyPÜnùö				

