

DATE

09/02/2023

PRODUCER

R.E.M. SRL

CUSTOMER

BURGO SORA

PRODUCT

MARELLI NV225M6 N COMM 2023
0067 N REM 15950

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.13282	10.2	PASS	7.7	0.5	PASS
Phase 2			0.13216		PASS			
Phase 3			0.13216		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1457	6.4	3.220 m	0.1	6.4	46.94	0	GO	99.9
Phase 2	1457		3.223 m			46.94		GO	
Phase 3	1457		3.220 m			46.94		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1041	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1042	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	857	428	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

