

DATE

11/01/2024

PRODUCER

R.E.M. SRL

CUSTOMER

BURGO SORA

PRODUCT

MARELLI 355LX 4 N_G11432 Comm
2023 0821

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.01512	15.44	PASS	7.7	0.2	PASS
Phase 2			0.01512		PASS			
Phase 3			0.01515		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1200	5.2	696.7 u	0.5	6	39.02	0	GO	99.5
Phase 2	1200		699.9 u			39.02		GO	
Phase 3	1200		699.9 u			39.02		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1053	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1054	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	342	342	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

