

DATE

16/01/2024

PRODUCER

R.E.M. SRL

CUSTOMER

BURGO SORA

PRODUCT

MARELLI A4C225M2 B3 N COMM
2023 0822 N REM 11703

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.23955	14.38	PASS	7.7	0.2	PASS
Phase 2			0.23915		PASS			
Phase 3			0.2391		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1457	5.2	5.488 m	0.2	6	61.4	1.8	GO	98
Phase 2	1457		5.492 m			61.4		GO	
Phase 3	1435		5.484 m			62.5		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1131	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1131	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	928	571	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

