

DATE

18/01/2024

PRODUCER

R.E.M. SRL

CUSTOMER

BURGO SORA

PRODUCT

STATORE VEM SPEH 225M4
N_27688 0001 Comm 2023 0823

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.07849	15.84	PASS	7.7	0.8	PASS
Phase 2			0.07908		PASS			
Phase 3			0.0787		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1328	5.2	874.2 u	0	6	31.15	1.6	GO	98.4
Phase 2	1342		874.2 u			31.15		GO	
Phase 3	1328		874.2 u			31.67		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1131	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1118	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	928	500	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

