

DATE

14/06/2023

PRODUCER

R.E.M. SRL

CUSTOMER

BUZZI UNICEM

PRODUCT

MOTORE MARELLI N REM 0405

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.19599	20.37	PASS	7.7	0.8	PASS
Phase 2			0.19674		PASS			
Phase 3			0.19755		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1135	5.2	556.0 u	0.8	5	35	0	GO	99.2
Phase 2	1157		560.3 u			35		GO	
Phase 3	1157		560.3 u			35		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1041	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1042	782.2	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	714	357	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

