

DATE

03/01/2024

PRODUCER

R.E.M. SRL

CUSTOMER

BUZZI BARLETTA

PRODUCT

SIEMENS 1LG6259 N Comm 2023
0877 N Rem 16321 (prima del

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.0432	14.82	PASS	7.7	0.6	PASS
Phase 2			0.04321		PASS			
Phase 3			0.04295		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1535	5.2	3.969 m	1.6	5	61.76	0	GO	98.4
Phase 2	1535		3.905 m			61.76		GO	
Phase 3	1535		3.924 m			61.76		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1067	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1067	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	857	535	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

